

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/6/2025	78430

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	12/13/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH429147 with new twp pump DH921664 Serena Boleto (Upper Prov) 515 Sandy Bank Rd Media, Pennsylvania 19063-1334 Technician Pat Brady Arrived on site and found pump DH429147 in alarm and not running panel read overpressure and brown out performed meter readings and brown to red and black were incorrect and due to age of pump installed a new upper Providence core DH00921664 and secured panel to the wall pump pumped down and shut off at 6.2 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00
1	Consumables	Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants			22.9925	22.99

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$322.99
	Sales Tax (0.0%)	\$0.00
	Total	\$322.99
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$322.99