

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice


| Date | Invoice # |
|----------|-----------|
| 2/2/2025 | 79027 |

| |
|---|
| Bill To |
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 |

| |
|---|
| Ship To |
| Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | | Project |
|------------|--------|-----|-----------|----------|--|---------|
| | Net 30 | NB | 2/2/2025 | | | |

| Qty | Item Code | Description | Price Each | Amount |
|-----|-----------|--|------------|--------|
| 1 | Emergency | <p>Repair DH433614</p> <p>David & Jenna Miller (Upper Prov) 215 Yarmouth Lane Media, PA 19063</p> <p>Date of service 2/2/25: Technician Nick Butkewicz</p> <p>Arrived on site (UPPER PROVIDENCE) and the pump was in alarm. I performed my meter checks and found that the switches could be bad. I checked the voltage because the homeowner said that was an issue in the past. Voltage was fine at 240v. I popped the lid and there was a few feet of water in there. I pulled pump# DH433614 and inspected it. The pump was in good shape and was rebuilt about 7 or 8 years ago. The switches were definitely corroded and needed to be replaced. So I put new switches in. It has a MCB in the control housing and I Megged the motor and it was GOOD. The stator looked a little swollen so I replaced that too. I put the pump back in and it pumped the station out of alarm and shutoff off. It ran at 6.4 Amps. Job complete.</p> <p>Emergency Weekend/After Hours Rate</p> | 200.00 | 200.00 |



All material remains the property of Site Specific Design until final payment.

Subtotal

Sales Tax (0.0%)

Total

Payments/Credits

Total Due

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice

| Date | Invoice # |
|----------|-----------|
| 2/2/2025 | 79027 |

| Bill To |
|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 |

| Ship To |
|---|
| Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | | Project |
|------------|--------|-----|-----------|----------|--|---------|
| | Net 30 | NB | 2/2/2025 | | | |

| Qty | Item Code | Description | Price Each | Amount |
|-----|---------------------|--|------------|--------|
| 1 | 7290 | PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01 | 65.11 | 65.11 |
| 1 | 7291 | PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02 | 65.11 | 65.11 |
| 1 | 8203 | STATOR/LINER ASSY EXTREME NC0039G01 | 88.196 | 88.20 |
| 1 | Labor Nick Butke... | Emergency Labor Nick Butkewicz | 225.00 | 225.00 |

All material remains the property of Site Specific Design until final payment.

Subtotal \$643.42

Sales Tax (0.0%) \$0.00

Total \$643.42

Payments/Credits \$0.00

Total Due \$643.42

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.