

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/5/2025	79068

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	2/5/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH43145 with new twp pump DH923304 Denise Derosa (Upper Prov) 61 Steeplechase Dr Media, Pennsylvania 19063-1952 Date of service 2/5/25 Technician Sebastian Gonzalez Arrived in site to find panel in alarm. Performed meter readings and all readings to pump were bad except voltage to pump and panel 240V I wasn't getting any amp draws when I tried to bump pump. I pulled pump DH431445 and saw that tag said pump was from 02/2012 I went to upper Prov shed to grab customer new core #DH00923304. I put new core into station and ran pump to alarm. And had customer run water so I can run pump to its normal cycle. Performed my last meter readings and everything checked out good.				
1	Service/Ins 1 Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
	Payments/Credits	\$0.00
	Total Due	\$300.00