

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
2/10/2025	79114

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	2/10/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH402780 with new Twp pump DH921732  Chris Busche (Upper Prov) 1205 Hunt Club Ln Media, Pennsylvania 19063-2002  Date of service 2/10/25 Technician Pat Brady  Arrived on site and found pump DH402780 in high level and over pressure alarm performed meter readings all readings were incorrect pulled pump for further evaluation and found pump corroded beyond repair and due to the age of the pump installed new upper Providence core DH00921732 pump pumped out of alarm and shut off at 5.9 amps pump is running correctly				
1 1.5	Service/Ins Labor-PB	Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 195.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Subtotal</b>	\$365.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$365.00
	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$365.00