

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/17/2025	79218

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	2/17/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433581 with new twp pump DH924033 Michael Mooney 41 Paxton Hallow Rd Media PA 19063 Date of service 2/17/25 Technician Pat Brady Arrived on site and found pump DH433581 in alarm called to run and not running performed meter readings and all readings were incorrect went to pull pump for further evaluation and found station flooded bunch of cable bunched up under the water pulled pump and found heavily corroded control housing and station was full of rags and wipes.cleaned out station the best I could due to age of the pump installed new core DH00924033 pump pumped down and shut off at 6.1 amps pump is running correctly water				
1 2.5	Service/Ins Labor-PB	Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 325.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal \$495.00
	Sales Tax (0.0%) \$0.00
	Total \$495.00
	Payments/Credits \$0.00
	Total Due \$495.00