

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/17/2025	79222

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	2/17/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH420623 with new twp pump DH934061 Mark Belczyk 1971 Colt Rd Media PA 19063 Service Date 2/17/25 Technician Pat Brady Arrived on site and found pump DH420623 in high level alarm called to run but not running there is proper voltage to the pump and cable megged good al other readings were incorrect due to age of pump installed new upper Providence core DH00934061 has been installed and cycled pump pumped down and shut off at 6.2 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee Labor rate for Pat			170.00	170.00
1	Labor-PB				130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.