

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/17/2025	79229

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	2/17/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433007 with new twp pump DH923321 Kap Chong 1891 Colt Rd Media PA 19063 Date of service 2/17/25 Technician Pat Brady Arrived on site and found pump DH433007 in high level alarm running and not pumping out performed meter readings all readings were incorrect pull pump for further evaluation and due to age installed new upper Providence core DH00923321 pump pumped down and shut off at 5.9 amps pump is running correctly				
1 1.5	Service/Ins Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			170.00 130.00	170.00 195.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal \$365.00
	Sales Tax (0.0%) \$0.00
	Total \$365.00
	Payments/Credits \$0.00
	Total Due \$365.00