

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/18/2025	79240

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	2/18/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH486360 with new twp pump DH934040 Stephanie Farrel 20 Indian Spring Rd Media PA 19063 Date of service 2/18/25 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm but the red light on panel was just blinking turning on and off. Reseted tbh breakers in panel and then pump and panel both kicked on. My guess was the panel had lost power which is why the panel was turning off and on. Performed meter readings and all readings to pump were good except switches and amps on pump were running on 4.8/5.0 amps. I pulled DH486360 and saw that pump was from 12/2011 I went to upper Prov shed to grab customer new core DH00934040 once I installed new pump I ran pump to alarm. And I also had customer run water so I can run pump to its normal cycle. Amps on new pump is 5.8 amps				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.