

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

| Date      | Invoice # |
|-----------|-----------|
| 2/13/2025 | 79192     |

| Bill To   | Ship To   |
|---|---|
| Upper Providence Township<br>Attn: Kevin Matson, Sewer Authority<br>935 N. Providence Road<br>Media, PA 19063 | Upper Providence Township<br>935 N Providence Road<br>610-566-5376<br>Media, PA 19063 |

| Cust. PO # | Terms       | Rep   | Ship Date | Ship Via |            | Project |
|------------|-------------|---|-----------|----------|------------|---------|
|            | Net 30      | PB  | 2/14/2025 |          |            |         |
| Qty        | Item Code   | Description   |           |          | Price Each | Amount  |
|            |             | Replace DH433136 with new twp pump DH934037<br><br>Mark Ghaul<br>104 Mansion Dr<br>Media PA 19063<br><br>Date of service 2/13/25<br>Technician Pat Brady<br><br>Arrived on site and found pump DH433136 not in alarm<br>performed meter readings all readings were incorrect<br>pulled pump for further evaluation and found control<br>housing corroded beyond repair and due to age of the<br>pump installed new upper Providence coreDH00934037<br>pump pumped down and shut off at 6.1 amps pump is<br>running correctl |           |          |            |         |
| 1          | Service/Ins | Service Call & Inspection Fee   |           |          | 170.00     | 170.00  |
| 1          | Labor-PB    | Labor rate for Pat  |           |          | 130.00     | 130.00  |



Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

|                         |          |
|-------------------------|----------|
| <b>Subtotal</b>         | \$300.00 |
| <b>Sales Tax (0.0%)</b> | \$0.00   |
| <b>Total</b>            | \$300.00 |
| <b>Payments/Credits</b> | \$0.00   |
| <b>Total Due</b>        | \$300.00 |