

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/19/2025	79274

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	2/19/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace pump n/a with new twp pump DH934021 Nathan Sunderhaus (Upper Prov) 320 Paxon Hollow Rd Media, Pennsylvania 19063-1118 Date of service 2/19/25 Technician Pat Brady Arrived on site and found station in alarm and panel read high level and run dry performed meter readings all readings were incorrect pulled pump for further evaluation there is no numbers on the pump and the control house is heavily corroded and rotor is locked up installed new upper Providence core DH00934021 pump has been installed and cycled pump pumped down and shut off at 6.2 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
2	Labor-PB	Labor rate for Pat			130.00	260.00

Subtotal	\$430.00
Sales Tax (0.0%)	\$0.00
Total	\$430.00
Payments/Credits	\$0.00
Total Due	\$430.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER

3/10/2025