

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
2/20/2025	78417

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	AD	12/12/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433750 with new pump DH923685 Michael Gewertz (Upper Prov) 130 Kingston Rd Media, Pennsylvania 19063-1853 Technician Pat Brady Arrived on site and found pump DH433750 not in alarm and not running meter were incorrect brown to red and black incorrect and low amps pulled pump and due to age installed new core.DH00923685 has been installed and cycled pump pumped down and shuts off at 5.8 amps.Pump is running correctly				
1	UD200A01A01AA	Core-ug-hw, 240V, CC, 7'C Installation of new Extreme Core w/2 yr warranty. Inspect installation, basin, valve and alarm panel. Inspect EQD & wiring. Remove old pump, identify cause of failure, if possible. Provide warranty documentation. Clean grease and debris accumulation in basin. Install new pump core and test, record performance. Dispose of old components and clean work area.			0.00 3,205.00	0.00 3,205.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$3,205.00
Sales Tax (0.0%)	\$0.00
Total	\$3,205.00
Payments/Credits	\$0.00
Total Due	\$3,205.00