

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

| Date | Invoice # |
|-----------|-----------|
| 3/10/2025 | 79525 |

| Bill To | Ship To |
|---|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 | Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | | Project | | | |
|------------|-----------|---|-----------|----------|------------|-------------------------|--|--|--|
| | Net 30 | SGon | 3/11/2025 | | | | | | |
| Qty | Item Code | Description | | | Price Each | Amount | | | |
| | | <p>Brought back DH934082 to Abington and replace with new twp pump DH935954</p> <p>James Tillilie (Upper Prov) 241 Foxcatcher Lane Media, PA 19063</p> <p>Date of service 3/10/25 Technician Sebastian Gonzalez</p> <p>Arrived on site to find panel in alarm. Performed meter readings and all readings to pump were good except I wasn't getting any amp draws on new pump. Before pulling pump DH00934082 I disconnected EQD so I can meg cables in panel and all readings came back good. Pulled pump out of station and checked switches switches were brand new I was getting 2 clicks when I was pulling on bladder but pump wasn't kicking on only the alarm was going off. Checked motor wires and I megged the wires and all readings to pump came back bad. I called Scott and informed him about the situation and he wants me to bring back old pump to shop to further evaluate it and go to upper Prov shed to grab customer new core DH00935954. Once I installed new core I ran pump to alarm. And had customer run water for me I tested pump</p> | | | | | | | |
| | | | | | | Subtotal | | | |
| | | | | | | Sales Tax (0.0%) | | | |
| | | | | | | Total | | | |
| | | | | | | Payments/Credits | | | |
| | | | | | | Total Due | | | |

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER


4-1-2025

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice

| Date | Invoice # |
|-----------|-----------|
| 3/10/2025 | 79525 |

| Bill To | Ship To |
|---|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 | Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.