

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice


Date	Invoice #
3/11/2025	79550

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	3/11/2025			

Qty	Item Code	Description	Price Each	Amount
		Replace DH511438 with new twp pump DH934066 Matt & Sharon Prior 451 Hillendale Rd Media, Pennsylvania 19063-2211 Date of service 3/11/25 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings and all readings to pump were good except switches to pump and I wasn't getting any amp readings. I pulled pump DH511438 and saw that pump was from 09/2014 I went to upper Prov shed to grab customer new core DH00934066 I installed new core into station and ran pump to alarm. And I also had customer run water for me so I can test pump to its normal cycle. Both times everything checked out good. I also megged cables to panel and readings came back good. Job completed		
1	Service/Ins	Service Call & Inspection Fee	170.00	170.00
1	Labor-SGon	Labor rate for Sebastian	130.00	130.00



Subtotal		\$300.00
Sales Tax (0.0%)		\$0.00
Total		\$300.00
Payments/Credits		\$0.00
Total Due		\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.