

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001




Invoice

215-887-3730

Date	Invoice #
3/22/2025	79768

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	NB	3/22/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH430196 with new twp pump DH00935958 Katelyn Oliver (Upper Prov) 205 Yarmouth Lane Media, PA 19063 Date of service 3/22/25 Technician Nick Butkewicz Arrived on site and the alarm was going off and the pump wasn't running. The panel read overpressure. I performed my meter checks and they were normal. I pulled pump# DH430196 and brought it to my truck. The station had quite a bit of water in it when I pulled the pump. It also had a good amount of rags and grease in it. I pulled some out. I advised the homeowner that grease and rags will cause issues for the pump. Since this is Upper Providence Township and the pump was around 13-14 years old I put a new pump in. I went to the shed and grabbed pump# DH00935958. I put that pump in the station and it cycled through and shutoff. Pump ran at 6.4 Amps. Job complete				
1	Emergency 1 Labor Nick Butke...	Emergency Weekend/After Hours Rate EmergencyLabor Nick Butkewicz			200.00 225.00	200.00 225.00



4-1-2025

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$425.00
Sales Tax (0.0%)	\$0.00
Total	\$425.00
Payments/Credits	\$0.00
Total Due	\$425.00