

UPTSA 2024 Pump Station Invoices

Upper Prov./Operations & Maintenance

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
4/5/2025	Upper Providence Township Sewer Authority	2673442	1930867	1	IS-C-WWTP-Lift & Pump Station Operations	\$7,240.33	Monthly O&M	\$7,240.33	6560005985
4/2/2025	Upper Providence	2673442	1930867	1	Infrastructure Services	\$4,182.00	April 1.2025, preformed annual full service maintenance on generators at Valley View, Rose Tree, Winer Street, Bortondale, Toftwoods and Media stations.	\$4,182.00	6588186267
Pump Station Total								\$11,422.33	

Upper Prov./Bortondale

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
4/4/2025	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a power failure alarm. Power still out upon arrival. Called in vacuum truck to maintain station.	\$631.28	6588186494
4/4/2025	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Pump Truck-OT	\$291.68	Maintained wet well.	\$1,166.72	6560006871
4/4/2025	Upper Providence/Bortondale	2673442	1930598	2	Project-C-Hours-Foreman-Mechanic	\$105.21	Checked station during power failure. Power was restored upon arrival. Reset both pumps. Observed proper operation before departure.	\$210.42	6588186495
Pump Station Total								\$2,008.42	

Upper Prov/Braves Trail

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
4/4/2025	Upper Providence/Braves Trail	2673442	1930600	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a lag alarm. Upon arrival found pump #2 had lost prime. Primed pump #2 and observed proper operation before departure.	\$157.82	6588186496
4/12/2025	Upper Providence/Braves Trail	2673442	1930600	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure. Power restored upon arrival. Observed proper operation before departure	\$157.82	6588187123
Pump Station Total								\$315.64	

Upper Prov/Rosetree Estates Upper

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
4/12/2025	Upper Providence/Rose Tree Upper	2673442	1930605	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure. Power restored upon arrival. Observed proper operation before departure	\$157.82	6588187128
Pump Station Total								\$157.82	

Upper Prov/Rosetree Estates Lower

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
4/3/2025	Upper Providence/Rose Tree Lower	2673442	1930603	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Troubleshoot biocide pump. The pump had lost prime. Replaced check valve within pump with spare onsite. Disconnected lines and primed pump. Observed proper operation before departure.	\$315.63	6588186299

4/3/2025	Upper Providence/Rose Tree Lower	2673442	1930603	3	Project-C-Hours-Mechanic	\$97.54	Troubleshoot bioxide pump. The pump had lost prime. Replaced check valve within pump with spare onsite. Disconnected lines and primed pump. Observed proper operation before departure.	\$292.62	6588186300
4/10/2025	Upper Providence/Rose Tree Lower	2673442	1930603	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a lag alarm. Upon arrival found pump #2 tripped at the breaker. Reset and tried to run pump #2 without success. Put Pump #1 in lead. Observed proper operation before departure.	\$631.28	6588186935
4/12/2025	Upper Providence/Rose Tree Lower	2673442	1930603	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure. Power restored upon arrival. Observed proper operation before departure	\$157.82	6588187124
4/28/2025	UPTSA/Rose Tree Estates Lower	2673442	1930603	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Troubleshoot pump #2. Pump is inoperable. Pulled pump #2 for replacement.	\$315.63	6588188691
4/28/2025	UPTSA/Rose Tree Estates Lower	2673442	1930603	3	Project-C-Hours-Mechanic	\$97.54	Troubleshoot pump #2. Pump is inoperable. Pulled pump #2 for replacement.	\$292.62	6588188692
4/29/2025	UPTSA/Rose Tree Estates Lower	2673442	1930603	9	Project-C-Hours-Foreman-Mechanic	\$105.21	Picked up spare pump. Cleaned wet well and installed new pump on side #2.	\$946.89	6588188836
4/29/2025	UPTSA/Rose Tree Estates Lower	2673442	1930603	6	Project-C-Hours-Mechanic	\$97.54	Picked up spare pump. Cleaned wet well and installed new pump on side #2.	\$585.24	6588188837
4/29/2025	UPTSA/Rose Tree Estates Lower	2673442	1930603	6	Project-C-Hours-Mechanic	\$97.54	Picked up spare pump. Cleaned wet well and installed new pump on side #2.	\$585.24	6560006946
4/29/2025	UPTSA/Rose Tree Estates Lower	2673442	1930603	4	Project-C-Hours-Pump Truck	\$194.45	Picked up spare pump. Cleaned wet well and installed new pump on side #2.	\$777.80	6560006947
4/30/2025	UPTSA/Rose Tree Estates Lower	2673442	1930603	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Picked up and delivered pump to be repaired.	\$315.63	6588188980
							Pump Station Total	\$5,216.40	

Upper Prov./Winters Street

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
4/12/2025	Upper Providence/Winter Street	2673442	1930611	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a power failure alarm. Upon arrival found generator running. System was going into lag alarm. Found an issue with alternator switch. Corrected issue and observed proper operation before departure.	\$631.28	6588187121
							Pump Station Total	\$631.28	