

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
4/29/2025	79160

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	4/29/2025			
Qty	Item Code	Description			Price Each	Amount
		Scott O'Donnell 120 Springfield Lake Rd Media, Pennsylvania 19063-18ND				
		Date of service 4/29/25 Technician Pat Brady				
		Arrived on site and found pump UPS#13p in high level alarm running not evacuating station Pump is a three phase pump I let customers know that I would be back had to run to shop to pick up a three phase pump DH732907 Return to site installed pump pumped down and shut off at 5.6 amps pump is running correctly brought back customer pump for evaluation/repair				
1	Labor-PB 1 Service/Ins	Labor rate for Pat Service Call & Inspection Fee			130.00 170.00	130.00 170.00

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

**OK TO PAY**  
**KEVIN MATSON, PE,**  
**OPERATIONS MANAGER**

05/09/2025