

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
4/1/2025	79841

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	3/27/2025			
Qty	Item Code	Description			Price Each	Amount
	DH914928	Elaine Gallo (Upper Prov) 545 South Avenue Media, PA 19063				
		Date of service 4/1/25 Technician Pat Brady				
		Arrived on site and found pump DH00914928 not in alarm took meter readings all readings are correct manually ran the pump amps are 5.8 pump is running correctly there was a big puddle out side of the station on the discharge side. I manually ran the pump again and the water started to come up from outside of the tank. I told the homeowner that I left a message with township and we are just waiting to hear back from them but for now to minimize use of water and that I turned the breakers off to the pump and soon as we hear back from them I will send them a text				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1.5	Labor-PB	Labor rate for Pat			130.00	195.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$365.00
	Sales Tax (0.0%)	\$0.00
	Total	\$365.00
	Payments/Credits	\$0.00
	Total Due	\$365.00