

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
4/1/2025	79891

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	4/1/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace A12629 with new twp pump DH934079 Lisa Miller (Upper Prov) 565 Rosemary Cir Media, Pennsylvania 19063-2235 Date of service 4/1/25 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm. Performed meter readings and all readings to pump were bad. Switches on pump weren't readings open nor closed. I also wasn't getting any amps on pump. I opened lid to station to find station not flooded but customer had an old 2K series pump #A12629 I pulled pump and replaced with new upper Prov core DH00934079. Once I installed new core I ran pump to alarm. And I also had customer run water so I can run pump to its normal cycle and everything checked out good. Performed my last meter readings and everything checked out good. Job completed.				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

