

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
4/4/2025	79959

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	4/4/2025			
Qty	Item Code	Description			Price Each	Amount
		Michelle McAllee (Upper Prov) 2111 Kimberwick Rd Media, Pennsylvania 19063-1949				
		Date of service 4/4/25 Technician Sebastian Gonzalez				
		Arrived on site to find panel not in alarm but there was a loud humming noise coming from the panel the contactor in panel was making the loud noise. I performed meter readings and all readings to pump and panel were good. Switches were good. Pump also had a MCB that the readings were .074. Lifted lid to station and saw that station wasn't flooded and pump was brand new just got installed 11/2024 I replaced contactor with a new one and humming stopped. I also had customer run water so I can cycle pump to alarm and it's normal cycle both times everything checked out good				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00
1	lc1d12g7	Contactor 120v			61.70	61.70

All material remains the property of Site Specific Design until final payment.

Subtotal	\$361.70
Sales Tax (0.0%)	\$0.00
Total	\$361.70
Payments/Credits	\$0.00
Total Due	\$361.70

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.