

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
4/4/2025	79961

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	4/4/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH387310 with new twp pump DH935957  Rob Joyce (Upper Prov) 481 W Rose Tree Rd Media, Pennsylvania 19063-2014  Date of service 4/4/25 Technician Sebastian Gonzalez  Arrived on site to find panel not in alarm. Performed meter readings and all readings to pump were good except switches on pump and amps on pump were running on 4.4 amps. I lifted lid to station to find station flooded. I pulled pump DH387310 and saw that pump was from 09/2010 I went to upper Prov shed to grab customer new core DH00935957 I installed new core into station and I ran pump to alarm. And I also had customer run water so I can run pump to its normal cycle and both times everything checked out good.  Amps on new pump is 5.8 amps				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

**OK TO PAY**  
**KEVIN MATSON, PE,**  
**OPERATIONS MANAGER**

05/09/2025