

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
4/24/2025	80267

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project			
	Net 30	SGon	4/24/2025						
Qty	Item Code	Description			Price Each	Amount			
		DH00914923 Craig Gratton 60 Diemer Dr Media PA 19063 Date of service 4/24/25 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm. Performed meter readings and all readings to pump were good switches were reading closed and amps on pump were running on 5.8 amps. Upon further inspection I noticed that the contactor in panel kept clicking from open to closed. I also noticed that there was a broken piece on PCB. Also the neutral wire on board was completely stuck wasn't able to unscrew it I replaced with new PCB and contactor stopped clicking from opened to closed and I also megged cables in panel and readings came back good. I also pulled pump and checked everything from switches to MCB and stator and everything checked out good megged motor wires once again and readings came back good. Repaired pump and ran pump to alarm and I had customer run water and everything checked out good.							
						Subtotal			
						Sales Tax (0.0%)			
						Total			
						Payments/Credits			
						Total Due			

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
4/24/2025	80267

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project			
	Net 30	SGon	4/24/2025						
Qty	Item Code	Description			Price Each	Amount			
1	Service/Ins 1 Labor-SGon 1 9543	pump number is DH00914923 Service Call & Inspection Fee Labor rate for Sebastian NB0072G21 Sentry Protect Panel PCB Board Alarm Replacement 240v			170.00 130.00 363.2101	170.00 130.00 363.21			
					Subtotal	\$663.21			
					Sales Tax (0.0%)	\$0.00			
					Total	\$663.21			
					Payments/Credits	\$0.00			
					Total Due	\$663.21			

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.