

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/2/2024	78256

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	12/2/2024			
Qty	Item Code	Description			Price Each	Amount
1	DH511424 2660 N Providence Rd Date of service 12/2/24 Technician Pat Arrived on site and found pump DH511424 not in alarm took meter readings all readings were correct.I had customer run some water and water was coming up out of the vent and not making it way into the station.I let the customer know that he will need to get a plumber.He asked if I could just help them . I stuck a garden hose into the vent and turned the water on nothing I pushed the hose in further and turned on the water and cleared the line station filled up pump went into alarm and out of alarm at 6.4 amps pump is running correctly 1 Service/Ins 1 Labor-PB	Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

	Subtotal	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
	Payments/Credits	\$0.00
	Total Due	\$300.00