

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/6/2024	78347

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	AD	12/6/2024			
Qty	Item Code	Description			Price Each	Amount
1	UD200A01A01AA 1 Installation of Ne...	Replace DH419317 with new pump DH921955 290 Appletree Dr Date of service 12/6/24 Technician Pat Brady Arrived on site and found pump DH419317 in alarm and not running. Performed meter readings and brown to red/black were incorrect. Went to pull pump station was flooded and the pump was heavily corroded. Due to the age of the pump installed new core DH00921955 pump has been installed and cycled pump pumps out of alarm and from on/off 3- seconds at 6.1 amps pump is running correctly Core-ug-hw, 240V, CC, 7'C Installation of new Extreme Core w/2 yr warranty. Inspect installation, basin, valve and alarm panel. Inspect EQD & wiring. Remove old pump, identify cause of failure, if possible. Provide warranty documentation. Clean grease and debris accumulation in basin. Install new pump core and test, record performance. Dispose of old components and clean work area.			0.00	0.00
1					3,111.00	3,111.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$3,111.00
Sales Tax (0.0%)	\$0.00
Total	\$3,111.00
Payments/Credits	\$0.00
Total Due	\$3,111.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.