

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
12/10/2024	78376

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	12/10/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins Labor-PB	Replace DH429124 with new twp pump DH921777 Pat Rexing (Upper Prov) 204 Birnam Wood Ln Media, Pennsylvania 19063-1055 Date of service 12/10/24 Technician Pat Brady Arrived on site and found pump DH429124 in alarm and not running all meter readings are incorrect.Pulled pump for further evaluation and found that the rotor was locked up and due to the age of the pump installed new upper Providence core DH00921777 pump pumped down and shut off at 6.1 amps pump is running correctly			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00