

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/16/2024	78438

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	12/16/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins 1 Labor-SGon	Replace DH433186 with new twp pump DH921722 860 Crum Creek Rd Date of service 12/16/24 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings meter readings and all readings were bad excepts switches voltage to pump and panel. Switches to pump were giving off high numbers and I wasn't getting any amp draws which indicated that pumps contact coil was burnt out. I opened lid to station and saw that station was flooded. I pulled pump DH433186 and saw that pump was from 04/2012 I went to upper Prov shed to grab customer a new core #DH00921722. I put new core into station and ran pump to alarm. I also had customer run water so I can run pump back into alarm and both times pump pumped everything down correctly. Performed my last meter readings and all readings were good. Job completed.	Service Call & Inspection Fee Labor rate for Sebastian	170.00 130.00	170.00 130.00	

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal \$300.00
	Sales Tax (0.0%) \$0.00
	Total \$300.00
	Payments/Credits \$0.00
	Total Due \$300.00