

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/16/2024	78450

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	12/16/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH496271 & DH496270 with new twp pumps DH921778 & DH921763 Ginger Lewis (Upper Prov) 24 Lakewood Dr Media, Pennsylvania 19063-1808 Date of service 12/16/24 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings and all readings to pump 1 and pump 2 were bad. Pump 1 was completely shot. No readings were coming from pump one except voltage from pump to panel. Readings to pump 2 were also bad switches and also amp readings were really low. I pulled both pumps DH496271/DH496270 I also saw that both pumps were from 2014 so I went to upper Prov shed to grab customer 2 new pumps DH00921778/DH00921763. Once I put both new pumps into station I ran pumps to alarm. And performed my last meter readings and everything checked out good. Job completed.				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$300.00