

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice

Date	Invoice #
12/26/2024	78555

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	12/26/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins Labor-SGon	Replace DH557234 with new twp pump DH921725 515 Idlewild cir Date of service 12/26/24 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings and all readings to pump were bad except voltage from pump to panel. Switches on pump were giving off high numbers. I wasn't getting any amp draws. I pulled pump DH557234 and saw that pump was from 09/2014 I went to upper Prov shed to grab customer new core DH00921725. I put new core into station and ran pump to alarm. And I also had customer run water so I can run pump to its normal cycle. Both times pump pumped everything down correctly. Job complete Service Call & Inspection Fee Labor rate for Sebastian		170.00 130.00	170.00 130.00	

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00