

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/2/2025	83708

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Project
	Net 30	PB	12/2/2025		
Qty	Item Code	Description		Price Each	Amount
		Repair DH826078 Gerald Halt (Upper Prov) 2252 E Deerfield Dr Media, Pennsylvania 19063-1834 Date of service 12/2/25 Technician Pat Brady Arrived on site and found pump DH826078 not in alarm and all meter readings were correct pulled pump for further evaluation and switches looked good stator was a little worn everything else checked out good home owner said that when he went to silence, the alarm that the button would not work. I changed out the stator reinstalled pump and showed home owner the the alarm button does work and cycled the pump twice pump pumped down and shut off at 5.9 amps job is completed			
1	Service/Ins	Service Call & Inspection Fee		170.00	170.00
2.5	Labor-PB	Labor rate for Pat		130.00	325.00
1	8203	STATOR/LINER ASSY EXTREME NC0039G01		88.196	88.20

All material remains the property of Site Specific Design until final payment.	Subtotal	\$583.20
	Sales Tax (0.0%)	\$0.00
	Total	\$583.20
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$583.20