

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/10/2025	83816

Bill To
Attn: Kevin Matson, Sewer Authority 935 N. Providence Road 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Project
	Net 30	PB	12/10/2025		
Qty	Item Code	Description		Price Each	Amount
		Repair DH00959794 Lou Yalisove (Upper Prov) 381 Highland Ave Media, Pennsylvania 19063-2207 Date of service 12/10/25 Technician Bryan/Pat Arrived on site to find panel in high level alarm with pump DH00959794 not running. Customer had shut off alarm breaker I also noticed that the breakers were tripped in the panel I reset and they tripped again. changed out the breakers flipped them on and pump pumped out of alarm and shut off at 6.1 amps turned breakers off took meter readings again all are correct Job is completed			
1	Service/Ins	Service Call & Inspection Fee		170.00	170.00
1.5	Labor-PB	Labor rate for Pat		130.00	195.00
1	Labor-BB	Labor rate for Bryan Beebee		130.00	130.00
1	Misc.	BREAKER, 2 POLE, 15A 9503		74.83	74.83
1	9504	BREAKER, 1 POLE, 15A		33.42	33.42

All material remains the property of Site Specific Design until final payment.	Subtotal	\$603.25
	Sales Tax (0.0%)	\$0.00
	Total	\$603.25
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	-\$300.00
	Total Due	\$303.25