

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/15/2025	83852

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Project
	Net 30	PB	12/15/2025		
Qty	Item Code	Description		Price Each	Amount
		Replace DH469783 with new twp pump DH00975037 John Voycik (Upper Prov) 643 S Orange St Media, Pennsylvania 19063-4011 Date of service 12/15/25 Technician Pat Brady Pump making loud noise when large amount of water used. Arrived on site and found pump DH469783 not in alarm and would not run took meter readings all were incorrect pulled for further evaluation and found station full of grease hair an other non flushable material.Pump heavily corroded and rotor was locked up.went to township shed for pump DH00975037 .I cleaned out station best I could informed homeowner what not to flush .installed new core DH00975037 pump pumped down and shut off at 6.1 pump is running correctly			
1	Service/Ins	Service Call & Inspection Fee		170.00	170.00
2.5	Labor-PB	Labor rate for Pat		130.00	325.00
1	Consumables	Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants		27.05	27.05

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$522.05
	Sales Tax (0.0%)	\$0.00
	Total	\$522.05
	Payments/Credits	\$0.00
	Total Due	\$522.05