

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
12/15/2025	83853

**Bill To**

Upper Providence Township  
Attn: Kevin Matson, Sewer Authority  
935 N. Providence Road  
Media, PA 19063

**Ship To**

Upper Providence Township  
935 N Providence Road  
610-566-5376  
Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Project
	Net 30	PB	12/15/2025		
Qty	Item Code	Description		Price Each	Amount
		DH420626  Craig Miller (Upper Prov) 481 Jacques Ln Media, Pennsylvania 19063-1914  Date of service 12/15/25 Technician Pat Brady  Overflowing. Arrived on site and found pump DH420626 not in alarm and all meter readings are correct. There is toilet paper coming out of the vent pipe few feet before the station. I pulled pump to see if the water was making it into the station it isn't. I explained to homeowner what was going on and he is going to have a plumber come out to clear the line.			
1	Service/Ins 1 Labor-PB	Service Call & Inspection Fee Labor rate for Pat		170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Subtotal</b>	\$300.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$300.00
	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$300.00

**OK TO PAY  
KEVIN MATSON, PE,  
OPERATIONS MANAGER**

01/08/2025