

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
12/17/2025	83893

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Project
	Net 30	PB	12/17/2025		
Qty	Item Code	Description		Price Each	Amount
		DH00959794 Lou Yalisove (Upper Prov) 381 Highland Ave Media, Pennsylvania 19063-2207 Date of service 12/17/25 Technician Pat Brady Pump in high level alarm. Arrived on site to evaluate pump DH00959794 Pump was in high level alarm and not running also wouldn't manually run. performed meter readings all readings were correct. Went to pull the pump for further evaluation and found discharge line was exposed on the outside of the station and frozen also the water in the dry well. I used a heat gun to thaw the discharge pulled the pump and the whole inside of the discharge tube was solid ice thaw that out. Took meter readings at the pump all were correct reinstalled pump pumped out of alarm and shut off at 6.0 amps cycled pump and same thing pumped down and shut off. everything is running correctly at this time			
2	Labor-PB	Labor rate for Pat		130.00	260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$260.00
	Sales Tax (0.0%)	\$0.00
	Total	\$260.00
	Payments/Credits	\$0.00
	Total Due	\$260.00