

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
1/24/2024	73452

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	AD	1/7/2024			
Qty	Item Code	Description			Price Each	Amount
1	UD200A01A01AA	Replace DH420921 with new pump DH879311 William Pohlhaus (Upper Prov) 216 South Ridley Creek Road Media, PA 19063 Date of service 1/7/24 Technician Pat Brady Upon arrival, found customers pump number DH420921 in alarm and not running. Removed customers pump for further evaluation in shop and installed SSD spare. Tested SSD spare for proper operation. DH430921 Motor megged bad. 1/19/24 Pat arrived on site to pull site spare but was unable to get down to the station due to the snow 1/24/24 Pat Arrived on site to pull site spare and install new core DH879311 pump pumped down and shut off at 6.3 amps pump is running correctly Core-ug-hw, 240V, CC, 7'C	0.00	0.00		

All material remains the property of Site Specific Design until final payment.

Subtotal
Sales Tax (0.0%)
Total
Payments/Credits
Total Due

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
1/24/2024	73452

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	AD	1/7/2024			
Qty	Item Code	Description			Price Each	Amount
1	Installation of Ne...	Installation of new Extreme Core w/2 yr warranty. Inspect installation, basin, valve and alarm panel. Inspect EQD & wiring. Remove old pump, identify cause of failure, if possible. Provide warranty documentation. Clean grease and debris accumulation in basin. Install new pump core and test, record performance. Dispose of old components and clean work area.			3,111.00	3,111.00
1	Emergency	Emergency Weekend/After Hours Rate			200.00	200.00
1	Labor-SC	Emergency Labor Rate for Sean			225.00	225.00
1	Labor-PB	Field Labor rate for Pat			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$3,666.00
Sales Tax (0.0%)	\$0.00
Total	\$3,666.00
Payments/Credits	\$0.00
Total Due	\$3,666.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.