

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
1/8/2024	73463

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	AD	1/8/2024			
Qty	Item Code	Description			Price Each	Amount
1	UD200A01A01AA	Replace A237758 with new pump DH858988 Michael Burke (Upper Prov) 785 Farnum Rd Media, Pennsylvania 19063-1613 Date of service 1/8/24 Technician Brandon Mauro Arrived on site to find old 2000 series pump from 2005 not functioning properly. Ill meter checks were incorrect. Found that the bearings of pump A237758 were completely shot. Pump motor had also failed due to seal failure. Found non flushable debris in station and removed by hand. Due to age of pump per Upper Prov Changed core plug to a permanent 1224 and installed new core DH858988. Homeowner was not home, but I was able to use the hose on site and a clean out to the station to test new pump. New pump runs 5.6 amps and is functioning properly. *There was no cores in township shed had to use one on my truck at Upper Prov price. \$2963.00 Core-ug-hw, 240V, CC, 7'C		0.00	0.00	

All material remains the property of Site Specific Design until final payment.

Subtotal
Sales Tax (0.0%)
Total
Payments/Credits
Total Due

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
1/8/2024	73463

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	AD	1/8/2024			
Qty	Item Code	Description			Price Each	Amount
1	Installation of Ne...	Installation of new Extreme Core w/2 yr warranty. Inspect installation, basin, valve and alarm panel. Inspect EQD & wiring. Remove old pump, identify cause of failure, if possible. Provide warranty documentation. Clean grease and debris accumulation in basin. Install new pump core and test, record performance. Dispose of old components and clean work area.			2,963.00	2,963.00
1	1224	PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core			0.00	0.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$2,963.00
Sales Tax (0.0%)	\$0.00
Total	\$2,963.00
Payments/Credits	\$0.00
Total Due	\$2,963.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.