

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
1/11/2024	73522

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/10/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433571 with new Twp pump DH876336 Bob Rennie 120 Gordon Dr Media PA 19063  Date of service 1/11/24 Technician Pat Brady  Arrived on site and found pump DH433571 in alarm and panel read high level and run dry. Took meter readings and all readings were incorrect and shorts to ground on every pump wire. pulled pump for further evaluation and found flooded station /EQD corroded control / motor housing. Due to age of the pump Installed new upper providence core DH876336 pump pumped down and shut off at 5.8 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee < Labor rate for Pat			150.00	150.00
2	Labor-PB				120.00	240.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$390.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$390.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$390.00