

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
1/11/2024	73527

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/11/2024			
Qty	Item Code	Description			Price Each	Amount
		Repair DH512134 Stephen Chermol 100 Water Mill LN Media PA 19063	Date of service 1/11/24 Technician Pat Brady	Pat arrived on site and found pump DH512134 in alarm panel read high level and run dry. Took meter readings and brown to red were incorrect and amps were low. Pulled pump for further evaluation and found corroded switches and a torn Stator everything else checked out good. changed out the switches and stator reinstalled pump pump pumped down and shut off at 5.9 amps pump is running correctly.		
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
2	Labor-PB	Labor rate for Pat			130.00	260.00
1	8203	STATOR/LINER ASSY EXTREME NC0039G01			92.6109	92.61
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings			68.374	68.37
1	7291	NB0083G01			68.374	68.37
		PRESSURE SWITCH, ALARM EXTREME w/ O-rings				
		NB0083G02				

All material remains the property of Site Specific Design until final payment.

Subtotal	\$659.35
Sales Tax (0.0%)	\$0.00
Total	\$659.35
Payments/Credits	\$0.00
Total Due	\$659.35

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.