

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
1/11/2024	73531

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/11/2024			
Qty	Item Code	Description			Price Each	Amount
	DH857080	Jason Centofanti (Upper Prov) 2170 Davis Drive Media, PA 19063				
		Date of service 1/11/24 Technician Pat Brady				
		Arrived on site and pump DH857080 wasn't in alarm Took meter readings all readings were correct cycled pump couple times pump went into and out of alarm and from on/off 32 seconds at 6.1 amps.Pulled pump for further evaluation and everything checked out good.Homeowner said they lost power for about 24 hours when power came back on the pump went into alarm then stopped after a couple of minutes.I explained to them that the water wasn't being pumped out during the 24 hours so when power came back on water level was up to the alarm that The pump pumped out of alarm and then off.				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.