

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
1/12/2024	73536

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/11/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace pump with new Twp pump DH876253 Benchmark School (Upper Prov) 2107 N Providence Rd (For House on property - 2105 N. Providence) Media, Pennsylvania 19063-1841				
		Date of service 1/12/24 Technician Pat Brady				
		Arrived on site and found Breakers turned off turned breakers back on pumpN/A was in alarm performed meter readings all readings were incorrect .Pump had corroded switches burnt control bracket and motor megged bad. Installed new upper Providence core DH876253 pump pumped down and shut off at 5.9 amps pump is running correctly				
2	Labor-PB	Labor rate for Pat			130.00	260.00
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$430.00
Sales Tax (0.0%)	\$0.00
Total	\$430.00
Payments/Credits	\$0.00
Total Due	\$430.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.