

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
1/20/2024	73660

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/20/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH510194 with new Twp pump DH876493 Cassandra Colburn (Upper Prov) 2141 Kimberwick Road Media, PA 19063				
		Date of service 1/20/24 Technician Pat Brady				
		Arrived on site and found pump DH510194 not in alarm and not running.went to take meter reading and found printed circuit board was burnt from slugs.Pulled pump for further evaluation and found heavily corroded motor/control housing . Due to age of pump installed new core DH876493 and changed out the circuit board.Cycled pump pumps down and shuts off at 6.1 amps pump is running correctly.				
1	Emergency	Emergency Weekend/After Hours Rate			200.00	200.00
2.5	Labor-PB	Emergency Labor rate for Pat			225.00	562.50
1	9543	NB0072G21 Sentry Protect Panel PCB Board Alarm Replacement 240v			337.1525	337.15

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$1,099.65
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$1,099.65
	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$1,099.65

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.