

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
1/22/2024	73663

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/22/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH425002 with new Twp pump DH876480 James Fox 60 Andrew Cir Media PA 19063  Date of service 1/22/24 Tehnicia Pat Brady & Joe Carroll  Arrived on site and found pump DH425002 in alarm and not pumping out pulled pump for further evaluation and found heavily corroded motor and control housings due to age of pump installed new upper Providence core DH876480 pump pumped down and shut off at 6.1 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee < Labor rate for Pat Labor Rate for Joe Carroll			170.00	170.00
1	Labor-PB				130.00	130.00
1	Labor-JC				130.00	130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$430.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$430.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$430.00