

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
1/25/2024	73715

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/24/2024			
Qty	Item Code	Description			Price Each	Amount
		Evaluate DH869936 Omar Abousoud /Yasmin Elkhashab(Upper Prov) 140 Kingston Road Media, PA 19063				
		Date of service 1/25/24 Technician Pat Brady				
		Red light. No alarm. Arrived on site and found pump DH869936 not in alarm and the alarm light wasn't on. Took meter readings from panel all correct and the cable megged good everything with the pump checked out good to. Pump is pumping down and off at 6.8 amps pump is running correctly.				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.