

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
5/1/2025	80368

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	4/30/2025			
Qty	Item Code	Description			Price Each	Amount
1 2.5	Service/Ins Labor-PB	Replace DH430201 with new twp pump DH00942225 Jessica Henry (Upper Prov) 206 Yarmouth Ln Media, Pennsylvania 19063-4331 Date of service 4/30/25 Technician Pat Brady Arrived on site and found pump DH430201 not in alarm performed meter readings and brown to black was.000 and bearings were noisy pulled pump for further evaluation found station had lots of grease cleaned out station the best I could and Due to age of the pump installed upper Providence New core DH00942225 has been installed and cycled pump pumped out of alarm and shut off at 6.2 amps pump is running correctly Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 325.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$495.00
	Sales Tax (0.0%)	\$0.00
	Total	\$495.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$495.00