

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
5/2/2025	80390

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/2/2025			
Qty	Item Code	Description			Price Each	Amount
1 2.5	Service/Ins Labor-PB	Replace DH544322 with new twp pump DH942296  Cindy Impicciatore (Upper Prov) 631 Rosemary Ln Media, Pennsylvania 19063-2237  Date of service 5/2/25 Technician Pat Brady  Arrived on site and found pump station below Grade and pump in alarm.Took meter readings all readings were incorrect.Dugout station pulled pump for further evaluation and found station full of wipes grease and other non flushable material.Control housing heavily corroded and the switches.Open up the control housing and found the contactor was stuck and the motor was flooded.cleared out station best I could and installed a new upper Providence core  Service Call & Inspection Fee Labor rate for Pat		170.00 130.00	170.00 325.00	

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$495.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$495.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$495.00