

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
5/6/2025	80433

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/6/2025			
Qty	Item Code	Description			Price Each	Amount
1 2.5	Service/Ins Labor-PB	Replace DH420598 with new twp pump DH00942224 Bart Cavanagh 1991 Kimberwick Rd Media, Pennsylvania 19063-1945 Date of service 5/6/25 Technician Pat Brady Arrived on site and found pump DH420598 not in alarm and the overlay said over pressure pump was running and not evacuating the station. Performed meter readings all readings were incorrect pulled pump for further evaluation found control housing and motor housing heavily corroded. Due to the age of the pump installed new upper Providence core DH00942224 pump pumped down and shut off a 5.8 amps pump is running correctly Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 325.00

Subtotal	\$495.00
Sales Tax (0.0%)	\$0.00
Total	\$495.00
Payments/Credits	\$0.00
Total Due	\$495.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.