

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
5/7/2025	80452

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/7/2025			
Qty	Item Code	Description			Price Each	Amount
3.5	Labor-PB 1 Service/Ins 1 8203	Repair DH543381 Anthony Piraino (Upper Prov) 172 Dam View Rd Media, Pennsylvania 19063-1832 Date of service 5/7/25 Technician Pat Brady Arrived on site and found pump DH543381 in alarm panel read run dry all meter readings were correct except amps. Pulled pump for further evaluation and found station full of grease. Evaluated pump found the stator was split everything else checked out good. Cleaned station out completely and shopped vac it. Changed out the stator reinstalled pump cycled pump 3 times pump Runs out of alarm and shuts off at 6.3 amps Pump is running correctly job completed Labor rate for Pat Service Call & Inspection Fee STATOR/LINER ASSY EXTREME NC0039G01				
				130.00	455.00	
				170.00	170.00	
				88.196	88.20	
					Subtotal	\$713.20
					Sales Tax (0.0%)	\$0.00
					Total	\$713.20
					Payments/Credits	\$0.00
					Total Due	\$713.20

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.