

UPTSA January 2024 Pump Station Invoices

Upper Prov./Operations & Maintenance

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
5/1/2024	Upper Providence Township Sewer Authority	2673442	1930867	1	IS-C-WWTP-Lift & Pump Station Operations	\$7,240.33	Monthly O&M	\$7,240.33	6560000215
							Pump Station Total	\$7,240.33	

Upper Prov/Braves Trail

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
5/30/2024	Upper Providence/ Braves Trail	2673442	1930600	2	Repair-C-Hour-Foreman-Mechanic	\$105.21	Responded to lag alarm.Cleaned floats, electrode and solenoid. Installed new ferrule on vacuum line for pump #2. Observed proper operation before departure.	\$210.42	6560004021
5/30/2024	Upper Providence/ Braves Trail	2673442	1930600		Repair-Materials	\$40.00	Ferrule	\$40.00	6560004021
5/30/2024	Upper Providence/ Braves Trail	2673442	1930600	2	Repair-C-Hour-Mechanic	\$97.54	Responded to lag alarm.Cleaned floats, electrode and	\$195.08	6560004022
							Pump Station Total	\$445.50	

Upper Prov./Media Station

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
5/23/2024	Upper Providence/Media Station	2673442	1930601	2	Repair-C-Hour-Foreman-Mechanic	\$105.21	Responded to high water alarm. Upon arrival, troubleshoot system. Cause for alarm unknown. Observed proper operation before departure.	\$210.42	6560003965
5/23/2024	Upper Providence/Media Station	2673442	1930601	2	Repair-C-Hour-Mechanic	\$97.54	Responded to high water alarm. Upon arrival, troubleshoot system. Cause for alarm unknown. Observed proper operation before departure.	\$195.08	6560003966
5/23/2024	Upper Providence/Media Station	2673442	1930601	2	Project-C-Pump Truck	\$194.45	Responded to high water alarm. Upon arrival, troubleshoot system. Cause for alarm unknown. Observed proper operation before departure.	\$388.90	6560003967
							Pump Station Total	\$794.40	