

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
5/2/2024	75063

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/3/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH460255 with new twp pump DH886082 Steven Stouffer 105 Mansion Dr Media PA 19063 Date of service 5/2/24 Technician Pat Brady Arrived on site and found pump dh460255 in high level alarm and not running all meter readings were incorrect .Pulled pump for further evaluation and found corroded top/control housing bolt holes corroded through.Installed a new upper Providence pump DH886082 pump pumped down and shut off at 5.8 amps pump is running correctly				
1	Labor-PB	Service Call & Inspection Fee < Labor rate for Pat			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$300.00

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER


06/11/2024