

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

| Date | Invoice # |
|-----------|-----------|
| 5/27/2024 | 75378 |

| Bill To | Ship To |
|---|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 | Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | | Project |
|------------|-------------|---|-----------|----------|------------|---------|
| | Net 30 | JohnS | 5/24/2024 | | | |
| Qty | Item Code | Description | | | Price Each | Amount |
| | | DH418307 Caemine Gentile 1911 Colt Rd Media PA 19063 | | | | |
| | | Date of service 5/27/24 Technician John Simons | | | | |
| | | Arrived on site to find sewer coming up from the ground outside of tank. Performed meter test and found shorts to ground from L1, L2 and manual run wires indicating issues with the controls. DH418307 still is operating properly but recommend replacing with a new core due to the age of pump and cost of repairs. The customer is going to have his discharge line repaired and then call us to have his pump replaced. Job complete. | | | | |
| 1 | Service/Ins | Service Call & Inspection Fee < | | | 170.00 | 170.00 |
| 1 | Labor-JS | Labor rate for John Simons | | | 130.00 | 130.00 |

All material remains the property of Site Specific Design until final payment.

| | |
|-------------------------|----------|
| Subtotal | \$300.00 |
| Sales Tax (0.0%) | \$0.00 |
| Total | \$300.00 |
| Payments/Credits | \$0.00 |
| Total Due | \$300.00 |

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.