

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
5/3/2024	75081

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/8/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH420934 with new twp pump DH886016 Sandra McGinley 1121 Ridley Creek Rd Media PA 19063 Date of service 5/3/24 Technician Pat Brady /Sebastian Arrived on site and found pumpDH420934 pulling high amps and red white readings are incorrect.Dueto age of pump installing upper Providence new core DH886016 pump pumped down and shut off at 5.9 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee < Labor rate for Pat			170.00	170.00
1.5	Labor-PB				130.00	195.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$365.00
	Sales Tax (0.0%)	\$0.00
	Total	\$365.00
	Payments/Credits	\$0.00
	Total Due	\$365.00