

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
5/9/2024	75146

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/15/2024			
Qty	Item Code	Description			Price Each	Amount
		Repair DH507182 Peter Vassiliou 107 Wilton Woods Ln Media PA 19063 Date of service 5/9/24 Technician Pat Brady Arrived on site and found pump DH507182 not in alarm or cheping all meter readings were correct.pulled pump for further evaluation and found corroded switches and everything else checked out good.Changed out the parts reinstalled pump pump pumped down and off at 6.3 amps pump is running correctly.				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1.5	Labor-PB	Labor rate for Pat			130.00	195.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings			68.374	68.37
1	7291	NB0083G01 PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02			68.374	68.37

All material remains the property of Site Specific Design until final payment.

Subtotal	\$501.74
Sales Tax (0.0%)	\$0.00
Total	\$501.74
Payments/Credits	\$0.00
Total Due	\$501.74

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.